
MEMORANDUM

TO: STAKEHOLDER ADVISORY GROUP

FROM: ERIN CARROL, PROJECT MANAGER - VEIC

SUBJECT: ERRATA MEASURES EFFECTIVE JUNE 1, 2014

DATE: 4/9/14

Cc: ANNETTE BEITEL

As utilities were developing their new programs utilizing the IL Statewide TRM Version 3, a number of errors were brought to VEIC's attention. To ensure that the correct values are applied to the new program year, VEIC has summarized the errors and created this errata memo to communicate the changes to the IL Stakeholders.

TRM Policy Document, Section 3.2.1, states that,

“TAC participants should notify the TAC when a TRM mistake or omission is found. If a significant mistake or omission is found in the TRM that results in an unreasonable savings estimate, the Program Administrators, Evaluators, TRM Administrator, and TAC will strive to reach consensus on a solution that will result in a reasonable savings estimate. For example, an unreasonable savings estimate may result from an error or omission in the TRM.

“In these limited cases where consensus is reached, the TRM Administrator shall inform the Evaluators to use corrected TRM algorithms and inputs to calculate energy and capacity savings, in addition to using the Commission-approved TRM algorithms and inputs to calculate savings. If the corrected TRM algorithms and inputs are stipulated for acceptance by all the parties in the Program Administrator's savings docket, then the corrected TRM savings verification values may be used for the purpose of measuring savings toward compliance with the Program Administrator's energy savings goals. Errors and omissions found in the TRM will be officially corrected through the annual TRM Update proceeding.”

It is our belief and understanding that the following measures have a consensus of the Program Administrators, Evaluators and the TAC. We have used the term ‘errata’ to describe these measures, and in accordance with the TRM Policy Document, the Evaluators may use these measures during evaluation of the current program year (in addition to the measures in Version 3.0 of the TRM).

For ease of use and convenience, VEIC will compile a stand-alone document of the errata measures by May 31st, 2014. In the meantime, copies of the errata documents themselves are presently available through the SharePoint tracker for each of the following measures.

Summary of Errata Measures

Section	Measure Name	Measure Code	Brief Summary of Change
4.4	HVAC	N/A	Added EFLH for Heat Pump Systems, PTAC/PTHP and Unitary AC
4.4.13	Package Terminal Air Conditioner	CI-HVC-PTAC-V05-140601	Retrofit cost information updated
4.4.19	Demand Control Ventilation	CI-HVC-DCV-V02-14060	Therm_Saving_Factor and Elec_Saving_Factor updated with final values
5.3.4	Duct Insulation and Sealing	RS-HVC-DINS-V03-140601	Input capacity update
5.4.3	Heat Pump Water Heaters	RS-HWE-HPWH-V03-140601	Coincidence factor reference update